

## Attachment L - Results Summary Lead in Water Sample

School Name: Gloucester City BOE - Cold Springs School

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
1S	38-0421-CS01	Rm 117 triple sink; middle one	2.69	No
2S	38-0421-CS02	Rm 117 single sink	2.04	No
3WF	38-0421-CS03	Rm 115 Water Fountain	1.48	No
4WF	38-0421-CS04	Rm 114 Water Fountain	1.15	No
5WF	38-0421-CS05	Rm 113 Water Fountain	ND	No
6WF	38-0421-CS06	Rm 112 Water Fountain	ND	No
7WF	38-0421-CS07	Rm 111 Water Fountain	ND	No
8WF	38-0421-CS08	Rm 110 Water Fountain	ND	No
9WF	38-0421-CS09	Rm 109 Water Fountain	ND	No
10WF	38-0421-CS10	Rm 108 Water Fountain	ND	No
11WF	38-0421-CS11	Rm 106 Water Fountain	ND	No
12WF	38-0421-CS12	Water Fountain near bus drop off (left)	ND	No
13WF	38-0421-CS13	Water Fountain near bus drop off (right)	ND	No
14S	38-0421-CS14	Mens staff restroom near storage 1	1.96	No
15S	38-0421-CS15	Boys restroom sink near storage 1	1.21	No
16S	38-0421-CS16	Girls restroom sink near storage 1	ND	No
17S	38-0421-CS17	Womans staff restroom sink near storage 1	ND	No
18WF	38-0421-CS18	Rm 102 Water Fountain	ND	No
19WF	38-0421-CS19	Rm 103 Water Fountain	ND	No
20WF	38-0421-CS20	Rm 100 Water Fountain	ND	No

Action Level (AL)  $\geq$ 15.5 parts per billion (ppb)

## Attachment L - Results Summary Lead in Water Sample

School Name: Gloucester City BOE - Cold Springs School

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
21WF	38-0421-CS21	Rm 101 Water Fountain	ND	No
22EW	38-0421-CS22	Nurses office eyewash sink	ND	No
23S	38-0421-CS23	Nurses office restroom sink	ND	No
24WF	38-0421-CS24	Boys locker room; restroom Water Fountain-right side	ND	No
25WF	38-0421-CS25	Boys locker room; restroom Water Fountain-left side	ND	No
26S	38-0421-CS26	Boys locker room; Restroom Sink	ND	No
27WF	38-0421-CS27	Girls locker room; Restroom Water Fountain-right	ND	No
28WF	38-0421-CS28	Girls locker room; Restroom Water Fountain-left	ND	No
29S	38-0421-CS29	Girls locker room; Restroom sink	ND	No
30S	38-0421-CS30	Main office kitchen sink	1.77	No
31S	38-0421-CS31	Main office conference room sink	14.2	No
32S	38-0421-CS32	Main office restroom sink; left near conf rm	ND	No
33S	38-0421-CS33	Main office restroom sink; right side end of hall	ND	No
34WF	38-0421-CS34	Main lobby area Water Fountain; left side	ND	No
35WF	38-0421-CS35	Main lobby area Water Fountain; right side	ND	No
36S	38-0421-CS36	Girls restroom sink across from main office-1st sink	1.04	No
37S	38-0421-CS37	Boys restroom sink scross from main office-1st sink	1.5	No
38WF	38-0421-CS38	Rm 127 Water Fountain	ND	No
39WF	38-0421-CS39	Rm 126 Water Fountain	ND	No
40WF	38-0421-CS40	Rm 125 Water Fountain	ND	No

Action Level (AL)  $\geq 15.5$  parts per billion (ppb)

## Attachment L - Results Summary Lead in Water Sample

School Name: Gloucester City BOE - Cold Springs School

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
41WF	38-0421-CS41	Rm 124 Water Fountain	ND	No
42WF	38-0421-CS42	Rm 123 Water Fountain	ND	No
43WF	38-0421-CS43	Rm 122 Water Fountain	ND	No
44WF	38-0421-CS44	Rm 121 Water Fountain	ND	No
45WF	38-0421-CS45	Rm 120 Water Fountain	ND	No
46WF	38-0421-CS46	Rm 119 Water Fountain	ND	No
47S	38-0421-CS47	Community Room 118; Double sink near window	4.04	No
48S	38-0421-CS48	Community Room 118; Single sink	6.74	No
49S	38-0421-CS49	Faculty Lounge; Mens restroom sink	1.16	No
50S	38-0421-CS50	Faculty Lounge; Womens restroom sink	2.51	No
51S	38-0421-CS51	Faculty Lounge Kitchen Sink	ND	No
52S	38-0421-CS52	Sink across from stove; next to coffee prep area	ND	No
53S	38-0421-CS53	Kitchen steamer sink	6.1	No
54I	38-0421-CS54	Kitchen ice machine	ND	No
55S	38-0421-CS55	Kitchen sink across from ice machine	ND	No
56S	38-0421-CS56	kitchen restroom sink	1.12	No
57S	38-0421-CS57	Girls restroom sink near maintenance shop-1st one	ND	No
58S	38-0421-CS58	Boys restroom sink near maintenance shop-1st one	ND	No
59WF	38-0421-CS59	Water Fountain across from maint office-left side	ND	No
60WF	38-0421-CS60	Water Fountain across from maint office-right side	ND	No

Action Level (AL)  $\geq$ 15.5 parts per billion (ppb)

## Attachment L - Results Summary Lead in Water Sample

School Name: Gloucester City BOE - Cold Springs School

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
61S	38-0421-CS61	Sink; Mrs. Driscoll's office	ND	No
62S	38-0421-CS62	Faculty lounge; 2nd floor sink	2.61	No
63WF	38-0421-CS63	Water Fountain next to faculty lounge	ND	No
64WF	38-0421-CS64	Water Fountain next to media ctr	ND	No
65WF	38-0421-CS65	Rm 201 Water Fountain	2.79	No
66WF	38-0421-CS66	Rm 200 Water Fountain	ND	No
67WF	38-0421-CS67	Rm 203 Water Fountain	ND	No
68S	38-0421-CS68	Rm 202 sink	ND	No
69WF	38-0421-CS69	Rm 205 Water Fountain	ND	No
70WF	38-0421-CS70	Rm 204 Water Fountain	ND	No
71WF	38-0421-CS71	Rm 207 Water Fountain	ND	No
72S	38-0421-CS72	Rm 206 Water Fountain	1.38	No
73S	38-0421-CS73	Womans faculty restroom sink across from storage 9	1.92	No
74S	38-0421-CS74	Girls restroom sink across from storage 9	ND	No
75S	38-0421-CS75	Boys restroom sink across from storage 9	2.47	No
76S	38-0421-CS76	Mens faculty restroom sink across from storage 9	ND	No
77WF	38-0421-CS77	Water Fountain next to storae 9; left side	ND	No
78WF	38-0421-CS78	Water Fountain next to storage 9; right side	ND	No
79WF	38-0421-CS79	Rm 211 Water Fountain	ND	No
80WF	38-0421-CS80	Rm 213 Water Fountain	ND	No

Action Level (AL)  $\geq 15.5$  parts per billion (ppb)

## Attachment L - Results Summary Lead in Water Sample

School Name: Gloucester City BOE - Cold Springs School

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
81WF	38-0421-CS81	Rm 214 Water Fountain	ND	No
82WF	38-0421-CS82	Rm 215 Water Fountain	ND	No
83WF	38-0421-CS83	Rm 216 Water Fountain	ND	No
84WF	38-0421-CS84	Rm 217 Water Fountain	ND	No
85WF	38-0421-CS85	Rm 218 Water Fountain	ND	No
86WF	38-0421-CS86	Rm 219 Water Fountain	ND	No
87WF	38-0421-CS87	Rm 220 Water Fountain	ND	No
88WF	38-0421-CS88	Rm 221 Water Fountain	ND	No
89WF	38-0421-CS89	Rm 222 Water Fountain	ND	No
1AWF	38-0421-CS90	Rm P-100 Water Fountain	ND	No
2AWF	38-0421-CS91	Rm P-098 Water Fountain	ND	No
3AWF	38-0421-CS92	Rm P-099 Water Fountain	ND	No
4AWF	38-0421-CS93	Rm P-096 Water Fountain	ND	No
5AWF	38-0421-CS94	Rm P-097 Water Fountain	ND	No
6AS	38-0421-CS95	Faculty Mens restroom sink	ND	No
7AS	38-0421-CS96	Girls restroom sink	ND	No
8AS	38-0421-CS97	boys restroom sink	ND	No
9AS	38-0421-CS98	Faculty womens restroom sink	ND	No
10AWF	38-0421-CS99	P-095 Water Fountain	2.76	No
11AS	38-0421-CS100	Faculty lounge sink	ND	No

Action Level (AL) ≥15.5 parts per billion (ppb)

## Attachment L - Results Summary Lead in Water Sample

School Name: Gloucester City BOE - Cold Springs School

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
12AWF	38-0421-CS101	ECC Main entrance Water Fountain-left side	ND	No
13AWF	38-0421-CS102	ECC Main entrance Water Fountain-right side	ND	No
14AS	38-0421-CS103	First sink kitchen entrance	1.08	No
15AS	38-0421-CS104	Kitchen sink near coffee prep station	ND	No
16AWF	38-0421-CS105	Rm P-093 Water Fountain	ND	No
17AWF	38-0421-CS106	Rm P-094 Water Fountain	3.18	No
18AWF	38-0421-CS107	Rm P-091 Water Fountain	ND	No
19AWF	38-0421-CS108	Rm P-092 Water Fountain	ND	No
20AWF	38-0421-CS109	Rm P-089 Water Fountain	ND	No
21AWF	38-0421-CS110	Rm P-090 Water Fountain	ND	No
22AWF	38-0421-CS111	Rm P-253 Water Fountain	ND	No
23AWF	38-0421-CS112	Rm P-252 Water Fountain	ND	No
24AWF	38-0421-CS113	Rm P-255 Water Fountain	ND	No
25AWF	38-0421-CS114	Rm P-254 Water Fountain	ND	No
26AWF	38-0421-CS115	Rm P-257 Water Fountain	ND	No
27AS	38-0421-CS116	Men's faculty restroom sink	ND	No
28AWF	38-0421-CS117	2nd Floor water fountain left (ECC Hallway)	ND	No
29AWF	38-0421-CS118	2rd Floor water fountain right (ECC Hallway)	ND	No
30AS	38-0421-CS119	2nd Floor women's faculty restroom (ECC Hallway)	ND	No
31AWF	38-0421-CS120	Rm P-0256	ND	No

Action Level (AL) ≥15.5 parts per billion (ppb)

