

Attachment L - Results Summary Lead in Water Sample

School Name: Gloucester City BOE - High School

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
1S	38-0420-GHS01	D-25 Sink	1.29	No
2S	38-0420-GHS02	Kitchen Staff Restroom Sink	2.94	No
3S	38-0420-GHS03	Kitchen Sink across from Stove	ND	No
4S	38-0420-GHS04	Kitchen Double Sink under window-right side	15.5	Yes
5S	38-0420-GHS05	Kitchen Double Sink under window-left side	8.51	No
6S	38-0420-GHS06	Kitchen Single Sink under window	3.98	No
7S	38-0420-GHS07	Little Sink across from oven	1.44	No
8WF	38-0420-GHS08	Water Fountain across from cafeteria-left side	ND	No
9WF	38-0420-GHS09	Water Fountain across from cafeteria-right side	ND	No
10S	38-0420-GHS10	Girls locker Rm; restroom sink-1st one	2.15	No
11S	38-0420-GHS11	Girls locker Rm; office restroom sink	3.54	No
12WF	38-0420-GHS12	Water Fountan in Girls Locker Room	ND	No
13WF	38-0420-GHS13	Water Fountain; Girls side of old gym	ND	No
14WF	38-0420-GHS14	Water Fountain; Boys side of old gym	10.7	No
15S	38-0420-GHS15	C-24; Wall 2 first sink	ND	No
16S	38-0420-GHS16	C-24; Wall 1 first sink	ND	No
17S	38-0420-GHS17	C-22 Sink	5.32	No
18S	38-0420-GHS18	Boys locker Rm; Restroom Sink-1st one	1.01	No
19S	38-0420-GHS19	Boys locker Rm; Office Restroom Sink	1.88	No
20S	38-0420-GHS20	Boys Coaches loker Rm; Office Sink	1.61	No

Action Level (AL) ≥15.5 parts per billion (ppb)

Attachment L - Results Summary Lead in Water Sample

School Name: Gloucester City BOE - High School

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
21S	38-0420-GHS21	C-29 Trainers Rm Sink	ND	No
22I	38-0420-GHS22	C-29 Trainers Rm Ice Machine	ND	No
23S	38-0420-GHS23	Staff restroom sink; girls-1st one	3.52	No
24WF	38-0420-GHS24	C Wing Water Fountain-left side	ND	No
25WF	38-0420-GHS25	C Wing Water Fountain-right side	ND	No
26S	38-0420-GHS26	Girls C-wing restroom sink; across from staff restroom	2.52	No
27S	38-0420-GHS27	C-Wing unisex restroom sink; right side	1.29	No
28S	38-0420-GHS28	C- Wing Staff boys restroom sink across from C-1	8.3	No
29S	38-0420-GHS29	C-1 First sink left side	5.76	No
30S	38-0420-GHS30	C-2 Sink	8.63	No
31WF	38-0420-GHS31	C-Wing Water Fountain outside of new gym; left side	ND	No
32F	38-0420-GHS32	C-Wing Water Fountain outside of new gym; right side	ND	No
33S	38-0420-GHS33	Boys Restroom sink across from school store-1st one	1.42	No
34S	38-0420-GHS34	Girls Restroom sink across from school store-1st one	ND	No
35S	38-0420-GHS35	Girls locker room; restroom sink-new gym	1.29	No
36S	38-0420-GHS36	Girls restroom sink; new gym foyer	ND	No
37WF	38-0420-GHS37	Water Fountain in new gym foyer; right side	ND	No
38WF	38-0420-GHS38	Water Fountain in new gym foyer; left side	ND	No
39S	38-0420-GHS39	Boys restroom sink; new gym foyer	ND	No
40S	38-0420-GHS40	Boys locker room; restroom sink in new gym	4.36	No

Action Level (AL) ≥15.5 parts per billion (ppb)

Attachment L - Results Summary Lead in Water Sample

School Name: Gloucester City BOE - High School

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
41E	38-0420-GHS41	Exterior faucet outside of fieldhouse	ND	No
42S	38-0420-GHS42	Girls restroom sink near E-2-1st one	ND	No
43WF	38-0420-GHS43	Water Fountain; Right side; bottom of B-Wing	ND	No
44WF	38-0420-GHS44	Water Fountain; Left side; bottom of B-Wing	ND	No
45S	38-0420-GHS45	Boys restroom sink across from Rm B-19-1st one	2.17	No
46S	38-0420-GHS46	B-19 Restroom Sink	ND	No
47S	38-0420-GHS47	Girls staff restroom sink across from the crossover	ND	No
48S	38-0420-GHS48	Boys staff restroom sink across from the crossover	ND	No
49WF	38-0420-GHS49	Water Fountain; Top of B-Wing-right side	ND	No
50WF	38-0420-GHS50	Water Fountain; Top of B-Wing-left side	ND	No
51S	38-0420-GHS51	Main Foyer girls restroom sink-1st one	ND	No
52S	38-0420-GHS52	Main Foyer boys restroom sink-1st one	4.42	No
53WF	38-0420-GHS53	A-Wing Water Fountain-Right	ND	No
54WF	38-0420-GHS54	A-Wing Water Fountain-Left	ND	No
55S	38-0420-GHS55	Main Office restroom sink across from A-8	ND	No
56S	38-0420-GHS56	A-10 Restroom Sink	ND	No
57S	38-0420-GHS57	A-12 Restroom Sink	ND	No
58S	38-0420-GHS58	A-12 Sink	1.11	No
59S	38-0420-GHS59	A-7 Sink	1.17	No
60S	38-0420-GHS60	H-7 Media Ctr girls restroom Sink	ND	No

Action Level (AL) ≥15.5 parts per billion (ppb)

Attachment L - Results Summary Lead in Water Sample

School Name: Gloucester City BOE - High School

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
61S	38-0420-GHS61	H-7 Media Ctr boys restroom Sink	1.17	No
62S	38-0420-GHS62	A-15 Station 1 sink; closest to front board	39	Yes
63S	38-0420-GHS63	A-17 Sink closest to board in front of classroom	3.22	No
64S	38-0420-GHS64	Prep Room Sink between A-17 & A-19	1.52	No
65S	38-0420-GHS65	A-19 Student station sink closest to door; right side	9.88	No
66EW	38-0420-GHS66	A-19 Eyewash Station	13.5	No
67EW	38-0420-GHS67	A-17 Eyewash Station	41.7	Yes
68EW	38-0420-GHS68	A-15 Eyewash Station	14.8	No
69WF	38-0420-GHS69	Water Fountain next to A-19; left	ND	No
70WF	38-0420-GHS70	Water Fountain next to D-11; right	ND	No
71S	38-0420-GHS71	D-3 Sink; left side	ND	No
72S	38-0420-GHS72	D-7B; middle sink near D-3 Side	ND	No
73S	38-0420-GHS73	D-7A; Middle sink near D-7B side	ND	No
74S	38-0420-GHS74	Boys restroom sink next o control room; 1st one	1.83	No
75S	38-0420-GHS75	Girls restroom sink next o control room; 1st one	1.01	No
76S	38-0420-GHS76	D-8; teachers station sink	12.9	No
77E	38-0420-GHS77	D-8; eyewash station	3.51	No
78S	38-0420-GHS78	Maintenance Rom; restroom sink	2.67	No
79S	38-0420-GHS79	D-12; teachers station sink	2.78	No
80EW	38-0420-GHS80	D-12; Eyewash station	14.2	No

Action Level (AL) ≥15.5 parts per billion (ppb)

