

## Attachment L - Results Summary Lead in Water Sample

School Name: Gloucester City Middle School

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
1S	39-0621-MS01	B107 Sink	2.27	No
2WF	39-0621-MS02	Water Fountain next to B107 -right side	ND	No
3WF	39-0621-MS03	Water Fountain next to B107 -left side	ND	No
4S	39-0621-MS04	Sink near stage	5.47	No
5S	39-0621-MS05	kitchen-handwashing sink L-side wall near stage	7.11	No
6S	39-0621-MS06	Kitchen-sink across from steamer	5.43	No
7S	39-0621-MS07	Kitchen-steamer sink	ND	No
8S	39-0621-MS08	Handwashing sink - middle of kitchen	19.7	Yes
9S	39-0621-MS09	kitchen-handwashing sink R-side wall not near stage	7.19	No
10S	39-0621-MS10	Sink across from dishwasher-left side	1.83	No
11S	39-0621-MS11	Sink across from dishwasher-right side	1.63	No
12S	39-0621-MS12	Kitchen sink across from B104B	15.1	No
13S	39-0621-MS13	Kitchen sink near C104B lockers	4.73	No
14S	39-0621-MS14	Faculty dining sink	9.57	No
15WF	39-0621-MS15	Gym-Water Fountain-girls' side near B101A-left side	ND	No
16WF	39-0621-MS16	Gym-Water Fountain-girls' side near B101A-right side	ND	No
17WF	39-0621-MS17	Gym-Water Fountain-boys' side near B101G-left side	ND	No
18WF	39-0621-MS18	Gym-Water Fountain-boys' side near B101G-right side	ND	No
19WF	39-0621-MS19	Water Fountain near A100D-right side	ND	No
20WF	39-0621-MS20	Water Fountain near A100D-left side	ND	No

Action Level (AL) ≥15.5 parts per billion (ppb)

## Attachment L - Results Summary Lead in Water Sample

School Name: Gloucester City Middle School

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
21S	39-0621-MS21	A103 Life skills rm - sink next to stove	7.49	No
22S	39-0621-MS22	A103 Life skills rm - white sink	20.20	Yes
23S	39-0621-MS23	A104 Nurse's office sink	5.26	No
24S	39-0621-MS24	A104 Nurse's office exam room sink	7.43	No
25S	39-0621-MS25	Sink in A101D	24.7	Yes
26WF	39-0621-MS26	Water Fountain next to C107 - left side	ND	No
27WF	39-0621-MS27	Water Fountain next to C107 - right side	ND	No
28S	39-0621-MS28	C103 Sink - Teacher's work room	5.75	No
29WF	39-0621-MS29	Water Fountain next to C111 - left side	ND	No
30WF	39-0621-MS30	Water Fountain next to C111 - right side	ND	No
31S	39-0621-MS31	Room C119 classroom sink	4.09	No
32S	39-0621-MS32	Room C119 bathroom sink	8.1	No
33WF	39-0621-MS33	Water Fountain next to C205 - left side	ND	No
34WF	39-0621-MS34	Water Fountain next to C205 - right side	ND	No
35S	39-0621-MS35	A201A Sink	5.77	No
36WF	39-0621-MS36	Water Fountain near A200C - right side	ND	No
37WF	39-0621-MS37	Water Fountain near A200C - left side	ND	No
38S	39-0621-MS38	C205 Double sink - left side	4.37	No
39S	39-0621-MS39	C205 Double sink - right side	8.06	No
40S	39-0621-MS40	C205 Single sink	8.79	No

Action Level (AL) ≥15.5 parts per billion (ppb)

## Attachment L - Results Summary Lead in Water Sample

School Name: Gloucester City Middle School

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
41S	39-0621-MS41	Room C206 Single sink	5.81	No
42S	39-0621-MS42	Room C206 Double sink - left side	6.22	No
43S	39-0621-MS43	Room C206 Double sink - right side	7.95	No
44WF	39-0621-MS44	Water Fountain next to C209 - left side	ND	No
45WF	39-0621-MS45	Water Fountain next to C209 - right side	ND	No
46S	39-0621-MS46	C217 first sink near window	27.8	Yes
47S	39-0621-MS47	C217 middle sink	17.3	Yes
48S	39-0621-MS48	C217 3rd sink near exit	15.9	Yes
49S	39-0621-MS49	C217 teacher's sink	13.3	No
50S	39-0621-MS50	C303 Sink	5.54	No
51S	39-0621-MS51	C307 1st sink left wall near entrance	14.9	No
52S	39-0621-MS52	C307 left wall middle sink	3.03	No
53S	39-0621-MS53	C307 3rd sink left wall near window	7.52	No
54S	39-0621-MS54	C307 1st sink near window right side	15.5	Yes
55S	39-0621-MS55	C307 middle sink right side	13.8	No
56S	39-0621-MS56	C307 3rd sink right wall near teachers sink	3.18	No
57S	39-0621-MS57	C307 Teacher's sink	5.56	No
58WF	39-0621-MS58	Water Fountain near C307 - left side	ND	No
59WF	39-0621-MS59	Water Fountain near C307 - right side	ND	No
60WF	39-0621-MS60	Water Fountain near C311 - left side	ND	No

Action Level (AL) ≥15.5 parts per billion (ppb)

### Attachment L - Results Summary Lead in Water Sample

School Name: Gloucester City Middle School

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
61WF	39-0621-MS61	Water Fountain near C311 - right side	ND	No
62S	39-0621-MS62	C319 Sink	7.94	No
	39-0621-MS63	Deionized blank	ND	

Action Level (AL) ≥15.5 parts per billion (ppb)