

The Gloucester City School District conducted lead in water testing of Gloucester City High School, Cold Springs School and Gloucester City Middle School. The testing was done by Environmental Design Inc., 5434 King Ave., Pennsauken NJ (888-306-4545). Testing was done in compliance with NJ State amendments N.J.A.C. 6A:26-1.2 & 12.4.

Gloucester City High School – All drinking water sources, water fountains and faucets, were in acceptable range. Out of range conditions were identified in (3) non drinking water sources. These areas have been posted as “Non Drinking Water Source”.

Cold Springs School – All water sources were in acceptable range.

Gloucester City Middle School – All drinking water sources, water fountains and faucets, were in acceptable range. Out of range conditions were identified in (7) non drinking water sources. Filters to remove any lead contaminants have been installed in all (7) locations by the NJSDA in June 2017.

For complete testing information on all schools please see the attached spreadsheets. If you have any questions please contact Facilities Director John Kenney @ 856-456-7000 x1524.